



NOTES:

1. PIPE AND FITTINGS ARE TO BE ASTM D3034, GASKETED 4" SDR 26 PVC UNLESS NOTED.
2. THE SERVICE SHALL BE INSTALLED PERPENDICULAR BETWEEN THE SEWER MAIN AND THE BUILDING ENTRY POINT WITH A UNIFORM SLOPE OF NOT LESS THAN 1/4" PER FOOT.
3. REFER TO MANUFACTURER'S SPECIFICATIONS FOR MAXIMUM JOINT DEFLECTION (TYPICALLY ONE DEGREE FOR PVC).
4. WHEN ABOVE GRADE, CLEAN OUT PLUGS SHALL BE CAST IRON METAL OR APPROVED EQUAL.

AUTHORITY DOES NOT PROVIDE BASEMENT SERVICE

SANITARY LATERAL SHALLOW SEWER DETAIL
NOT TO SCALE

REVISED 02/24/2026



PENNONI ASSOCIATES INC.
150 Ridge Road, Suite 2
Sellersville, PA 18960
T 215-257-5711 F 215-257-5766

SANITARY LATERAL-SHALLOW SEWER
PREPARED FOR:
PERKASIE REGIONAL AUTHORITY

DESIGNED BY:	JAR
CHECKED BY:	SRT
DATE:	4/04/96
DRAWING NO.	PRA-S010