



AUTHORITY DOES NOT PROVIDE BASEMENT SERVICE

NOTES:

1. PIPE AND FITTINGS ARE TO BE ASTM D3034, GASKETED 4" SDR 26 PVC UNLESS NOTED.
2. THE SERVICE SHALL BE INSTALLED PERPENDICULAR BETWEEN THE SEWER MAIN AND THE BUILDING ENTRY POINT WITH A UNIFORM SLOPE OF NOT LESS THAN 1/4" PER FOOT.
3. REFER TO MANUFACTURER'S SPECIFICATIONS FOR MAXIMUM JOINT DEFLECTION (TYPICALLY ONE DEGREE FOR PVC).
4. A COMPLETED TABLE SIMILAR TO THE TABLE SHOWN BELOW SHALL BE PLACED ON THE PLANS.
5. WHEN ABOVE GRADE, CLEAN OUT PLUGS SHALL BE CAST IRON METAL OR APPROVED EQUAL.

LOT NO.	INVERT IN AT BUILDING	DEGREE OF BEND A	DIMENSION B	DIMENSION C
1				

SANITARY LATERAL - DEEP SEWER DETAIL

NOT TO SCALE

REVISED 02/24/2026



PENNONI ASSOCIATES INC.
 150 Ridge Road, Suite 2
 Sellersville, PA 18960
 T 215-257-5711 F 215-257-5766

SANITARY SEWER-DEEP SEWER
 PREPARED FOR:
PERKASIE REGIONAL AUTHORITY

DESIGNED BY:	JAR
CHECKED BY:	SRT
DATE:	3/15/96
DRAWING NO.	PRA-S011