



**NOTES:**  
 ALL TESTING EQUIPMENT AND FITTINGS MUST BE DISINFECTED IN ACCORDANCE WITH PRA SPECIFICATIONS PRIOR TO TESTING.

**HYDROSTATIC PRESSURE TEST CONFIGURATION**  
 NOT TO SCALE

REVISED 7/30/2025



**PENNONI ASSOCIATES INC.**  
 150 Ridge Road, Suite 2  
 Sellersville, PA 18960  
 T 215-257-5711 F 215-257-5766

**PRESSURE TEST SCHEMATIC**  
 PREPARED FOR:  
**PERKASIE REGIONAL AUTHORITY**

DESIGNED BY:	JAR
CHECKED BY:	SRT
DATE:	4/08/96
DRAWING NO.	PRA-W12